



Maximum Floor Clear Span, feet	Maximum Anchor Bolt Spacing			
	Staggered 1/2" Diam. Anchor Bolts	Staggered 5/8" Diam. Anchor Bolts	Two 1/2" Diam. Anchor Bolts	Two 5/8" Diam. Anchor Bolts
8	18	20	36	40
10	16	18	32	36
12	14	18	28	36
14	12	16	24	32
16	10	14	20	28
18	9	13	18	26
20	8	11	16	22
22	7	10	14	20
24	7	9	14	18
26	6	9	12	18
28	6	8	12	16
30	5	8	10	16
32	5	7	10	14

#### NOTES:

1. Minimum ledger board nominal depth shall be 8". The thickness of the ledger board shall be a minimum of 2". Thickness of ledger board is in nominal lumber dimensions. Ledger board shall be minimum No.2 Grade.
2. Minimum edge distance shall be 2" for 1/2" Ø anchor bolts and 2 1/2" for 5/8" Ø anchor bolts.
3. Interpolation is permitted between floor spans.
4. Floor span corresponds to the clear span of the floor structure spanning between load bearing walls or beams.
5. Anchor bolts shall extend through the ledger to the center of the horizontal or vertical core thickness of the waffle-grid concrete cross section.
6. Minimum vertical distance between bolts shall be 1 1/2" for 1/2" Ø anchor bolts, and 2" for 5/8" Ø anchor bolts.
7. In order to use this table, the wall must be within the vertical reinforcement parameters. Consult an engineer beyond the parameters. This table is only valid for a service dead load of 15psf and a service live load of 40psf.
8. See Section 6 - Engineering in the LOGIX Product Manual for reinforcing details.



www.logixicf.com  
1-866-944-0153

The drawing represented herein is to be used as a reference guide only; the user shall check to ensure the drawing meets local building codes and construction practices by consulting local building officials and professionals, including any additional requirements. Logix reserves the right to make changes to the drawing without notice and assumes no liability in connection with the use of the drawing including modification, copying or distribution.

Drawing:  
5.6.2.14

Date:  
Jul 30/13

Title:

Anchor Tunnel – Floor Ledger Connection